

# Chameleon Flooring Pty Ltd

## TEST REPORT

**SCOPE OF WORK**

SPC flooring

**REPORT NUMBER**

190515001SHF-002

**TEST DATE(S)**

20201220 20201220

**ISSUE** [REDACTED]

20201220


**PAGES**

5

**DOCUMENT CONTROL NUMBER**

LFT-APAC-SHF-OP-10k(DL, 20 [REDACTED])

© 2020 INTERTEK



## Test Report

### Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

## Test Report

Issue Date: 2023-03-02 Intertek Report No. 190515001SHF-002  
Applicant: Chameleon Flooring Pty Ltd  
Address: 1981 MT COTTON ROAD CORNIBIA, QLD 4130 AUSTRALIA  
Attn: Wendy  
Test Type : Performance test, samples provided by the applicant.

### Product Information

<b>Product Name</b>	SPC flooring	<b>Brand</b>	Pallas Hybrid
<b>Sample Description</b>	Good Condition	<b>Sample Amount</b>	12 pieces
		<b>Received Date</b>	2023-02-15
<b>Sample ID</b>	<b>Model</b>	<b>Specification</b>	
S190515001SHF.001	Spotted gum	1540 x 182 x 7.5mm	


### Test Methods And Standards

<b>Test Standard</b>	EN ISO 9239-1:2010
<b>Specification Standard</b>	/
<b>Test Conclusion</b>	The samples were tested according to the above standards, and the results are shown in the following page.

#### Note:

1. This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

### Report Authorized

  
Sally Xie      Tod Qian  
Name: Sally Xie      Name: Tod Qian  
Title: Reviewer      Title: Project Engineer

# Test Report

Issue Date: 2023-03-02

Intertek Report No. 190515001SHF-002

**Test Items, Method and Results:****1 TEST STANDARD**

The test was conducted in accordance with EN ISO 9239-1:2010 Reaction to fire tests for floorings, Part 1: Determination of the burning behaviour using a radiant heat source. This test evaluates the wind-opposed burning behavior and spread of flame of horizontally mounted floorings exposed to a heat flux radiant gradient in a test chamber, when ignited with pilot flames.

**2 RESULTS AND OBSERATIONS**

Method	Parameter	Result
EN ISO 9239-1:2010	Critical flux (transverse), kW/m <sup>2</sup>	≥ 11.0
	Critical flux (longitudinal), kW/m <sup>2</sup>	≥ 11.0
	Smoke production, % minutes	313

**3 Test Photos**

Before test




After test

## Test Report


Issue Date: 2023-03-02

Intertek Report No. 190515001SHF-002

### Appendix A: Sample Received Photo



Front View (Test Face)



Back View

### Revision:

NO.	Date	Changes	Author	Reviewer
190515001SHF-002	2023-03-02	First issue	Tod Qian	Sally Xie